

**DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE  
MEDICINE**

**SANITARY CERTIFICATE**

**YEAR : 2024-2025**

**APPENDIX-3**

**(Chapter III Rule 24)**

**Tamil Nadu Education Rules**

L.DIS NO: **4145** /E2/2024

PERIOD: 2024-2025

Dated: **16** /07/2024

I hereby declare that I have inspected the **RMK SENIOR SECONDARY SCHOOL**, RSM Nagar, Sundarasozhavaram, Thiruverkadu, CH-77. Building and Premises on the day 15/07/2024 and Certify

**The Sanitary Certificate is issued with the following conditions:**

- \* That the accommodation provided for each of the several classes is sufficient for the maximum number of pupil taught therein and is properly ventilated and lighted.
- \* Provide safe drinking water to the Pupils and Staff.
- \* That the building is maintained in substantial repair that is neat and clean.
- \* That the latrine arrangements are adequate and satisfactory.
- \* That the supply of drinking water is wholesome and clean.
- \* That the premises are free from mosquito and housefly nuisance.
- \* That there is no stagnation of waste water.
- \* That is all other necessary respects the sanitation is good.
- \* Toilets & Urinals should be disinfected daily.
- \* Drinking water source should be chlorinated daily.
- \* All the class rooms should be disinfected daily as per the existing Guidelines of the Government.
- \* To avoid Mosquito breeding in the surrounding.
- \* Standard Operating Procedure regarding COVID should be strictly Adhered without fail.
- \* "No Smoking Area" Sign Board should be displayed in the Building Premises.
- \* If found any discrimination Certificate will be cancelled.

**Counter Signed**

**District Health Officer,  
Tiruvallur - 602 001.**

**BLOCK HEALTH SUPERVISOR**  
Govt. Primary Health Center  
Villivakkam Block  
Kollumedu, Tiruvallur Dist.

**APPENDIX-VIII**


**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

**NO 01 /BHS/2025**

**DATED: 11 /04/2025**

It is certified that an inspection team headed by **T.GOVINDARAJAN. BHS.** (Name of Officers with designation) from **PUBLIC HEALTH** (Name of Department / Office) inspected the **RMK Senior Secondary School, RSM Nagar, Sundarasoorthapuram, Thiruverkadu, Ch77** (Name & Address of the school) on **11/04/2025** (date of inspection) and found that the **RMK Senior Secondary School**, (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the central/state/U.T.Govt.

The above is valid for a period of **ONE YEAR**

  
**BLOCK HEALTH SUPERVISOR**  
**Govt. Primary Health Center**  
**Villivakkam Block**  
**Kottayam, Thiruvallur Dist.**  
Signature with seal:


Name : T.GOVINDARAJAN

Designation : Block Health Supervisor

To

RMK Senior Secondary SCHOOL  
RSM Nagar, Sundarasoorthapuram, Thiruverkadu, Ch 77

**(Name & Address of the Institution)**



CHENNAI METROPOLITAN WATER SUPPLY  
AND SEWERAGE BOARD  
WATER AND WASTE WATER TESTING LABORATORY  
QUALITY ASSURANCE WING, No.1, NEW AVADI ROAD,  
KILPAUK, CHENNAI – 600010.



ULR No : TC141662500000359F

TEST REPORT - DRINKING WATER

Doc.No: CMWSSB/FRM/7.8/01

Report No:	TR/2025/359-01	Report Issue Date:	26-03-2025	Page No	1 of 3
Challan No:	837	Challan Date:	24-03-2025	Amount (Rs)	2360/-

Client Name & Address  
& Contact No / Email.ID : R.M.K. Senior Secondary School ,  
R.S.M Nagar, Sundaracholapuram,  
Chennai 77.

Sample Name	: Water	Sample Description	: Drinking water
Sample Number	: 359	Sample Container	: Jerry Can
Sample Submitted by	: Customer	Location & Date	: RO Water, 24-03-2025
Sample Quantity	: 2 Litres	Sample Condition	: Good
Sample Received On	: 24-03-2025	Environmental Condition	: 23.0°C – 27.0°C
Test Commenced on	: 24-03-2025	Test Completed on	: 25-03-2025


S. No	Parameters	Unit		Result	Specification as per IS 10500:2012	
					Acceptable Limit	Permissible Limit
1	Colour	CU	IS 3025: Part 4: 2021	2	5	15
2	Odour	--	IS 3025: Part 5: 2018	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	IS 3025: Part 10: 2023	3.1	1	5
4	pH @ 25°C	--	IS 3025: Part 11: 2022	7.12	6.5 To 8.5	6.5 To 8.5
5	Electrical Conductivity @25°C	µS/cm	IS 3025: Part 14: 2013	110	-	-
6	Total Dissolved Solids	mg/L	IS 3025: Part 16: 2023	70	500	2000
7	Total Hardness as CaCO <sub>3</sub>	mg/L	IS 3025: Part 21: 2009	19	200	600
8	Calcium as Ca	mg/L	IS 3025: Part 40: 1991	4.4	75	200
9	Magnesium as Mg	mg/L	IS 3025: Part 46: 2023	1.9	30	100
10	Total Chloride as Cl	mg/L	IS 3025: Part 32: 1988	18	250	1000

*Lim*  
26/03/25  
Reviewed by  
Water Analyst

*PK*  
26/03/2025  
Authorised Signatory  
Pavai Kumar-Executive Engineer

Note:

1. The test results relate only to the items tested. & The result applied to the sample as received basis.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.



CHENNAI METROPOLITAN WATER SUPPLY  
AND SEWERAGE BOARD  
WATER AND WASTE WATER TESTING LABORATORY  
QUALITY ASURANCE WING, No.1, NEW AVADI ROAD,  
KILPAUK, CHENNAI – 600010.



TC-14166

ULR No : TC141662500000359F

TEST REPORT - DRINKING WATER

Doc.No: CMWSSB/FRM/7.8/01

Report No:

TR/2025/359-01

Report Issue Date:

26-03-2025

Page No

2 of 3

Challan No:

837


Challan Date:


24-03-2025

Amount (Rs)

2360/-


S. No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012	
					Acceptable Limit	Permissible Limit
11	Total alkalinity as CaCO <sub>3</sub>	mg/L	IS 3025: Part 23: 2023	29	200	600
12	Chlorine, Residual	mg/L	IS 3025: Part 26: 2021	<0.2	0.2	1.0
13	Ammonia as N	mg/L	IS 3025: Part 34: 1988	<0.1	0.5	No Relaxation
14	Nitrite as NO <sub>2</sub>	mg/L	IS 3025: Part 34: 1988	0.02	-	-
15	Fluoride as F	mg/L	IS 3025: Part 60: 2008	<0.2	1.0	1.5
16	Sulphate as SO <sub>4</sub>	mg/L	IS 3025: Part 24: Sec 1: 2022	10	200	400
17	Iron as Fe	mg/L	IS 3025: Part 53: 2003	0.15	0.3	No Relaxation

  
26/03/25  
Reviewed by  
Water Analyst


  
26/03/2025  
Authorised Signatory  
Pavai Kumar-Executive Engineer


Note:

1. The test results relate only to the items tested. & The result applied to the sample as received basis.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.



**CHENNAI METROPOLITAN WATER SUPPLY  
AND SEWERAGE BOARD  
WATER AND WASTE WATER TESTING LABORATORY  
QUALITY ASURANCE WING, No.1, NEW AVADI ROAD,  
KILPAUK, CHENNAI – 600010.**

TEST REPORT - DRINKING WATER				Doc.No: CMWSSB/FRM/7.8/01	
Report No:	TR/2025/359-02	Report Issue Date:	26-03-2025	Page No	3 of 3
Challan No:	837	Challan Date:	24-03-2025	Amount (Rs)	2360/-
Client Name & Address & Contact No / Email.ID		R.M.K. Senior Secondary School, R.S.M Nagar, Sundaracholapuram, Chennai 77.			
Sample Name	: Water	Sample Description	: Drinking water		
Sample Number	: 358	Sample Container	: Jerry Can		
Sample Submitted by	: Customer	Location & Date	: RO Water, 24-03-2025		
Sample Quantity	: 2 Litres	Sample Condition	: Good		
Sample Received On	: 24-03-2025	Environmental Condition	: 23.0°C – 27.0°C		
Test Commenced on	: 24-03-2025	Test Completed on	: 25-03-2025		
S. No	Parameters	Unit	Result	Specification as per IS 10500:2012	
				Acceptable Limit	Permissible Limit
18	Albuminoid Nitrogen	mg/L	CMWSSB SOP/001	0.08	-
19	Oxygen Absorbed @ 4 Hrs	mg/L	IS 3025: Part 63: 2007	0.87	-
20	Phosphate as P	mg/L	IS 3025: Part 31: Sec 1: 2022	0.01	-
<b>Remarks:</b> The tested sample is conformed to IS: 10500:2012 (RA: 2019) Drinking water specification with respect to above tested parameters.					
-----End of Test Report-----					
Reviewed by Water Analyst			 Authorised Signatory Pavai Kumar-Executive Engineer		
<b>Note:</b> 1. The test results relate only to the items tested. & The result applied to the sample as received basis. 2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory. 3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.					



CHENNAI METROPOLITAN WATER SUPPLY  
AND SEWERAGE BOARD  
WATER AND WASTE WATER TESTING LABORATORY  
QUALITY ASSURANCE WING, No.1, NEW AVADI ROAD,  
KILPAUK, CHENNAI – 600010.



ULR No : TC141662500000358F		TEST REPORT - DRINKING WATER		Doc.No: CMWSSB/FRM/7.8/01		
Report No:	TR/2025/358-01	Report Issue Date:	26-03-2025	Page No	1 of 3	
Challan No:	836	Challan Date:	24-03-2025	Amount (Rs)	2360/-	
Client Name & Address & Contact No / Email.ID :	R.M.K. Senior Secondary School , R.S.M Nagar, Sundaracholapuram, Chennai 77.					
Sample Name	: Water	Sample Description	: Drinking water			
Sample Number	: 358	Sample Container	: Jerry Can			
Sample Submitted by	: Customer	Location & Date	: Bore Well Water, 24-03-2025			
Sample Quantity	: 2 Litres	Sample Condition	: Good			
Sample Received On	: 24-03-2025	Environmental Condition	: 23.0°C – 27.0°C			
Test Commenced on	: 24-03-2025	Test Completed on	: 25-03-2025			
S. No	Parameters	Unit		Result	Specification as per IS 10500:2012	
					Acceptable Limit	Permissible Limit
1	Colour	CU	IS 3025: Part 4: 2021	5	5	15
2	Odour	--	IS 3025: Part 5: 2018	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	IS 3025: Part 10: 2023	7.2	1	5
4	pH @ 25°C	--	IS 3025: Part 11: 2022	7.48	6.5 To 8.5	6.5 To 8.5
5	Electrical Conductivity @25°C	µS/cm	IS 3025: Part 14: 2013	1330	-	-
6	Total Dissolved Solids	mg/L	IS 3025: Part 16: 2023	865	500	2000
7	Total Hardness as CaCO <sub>3</sub>	mg/L	IS 3025: Part 21: 2009	520	200	600
8	Calcium as Ca	mg/L	IS 3025: Part 40: 1991	136	75	200
9	Magnesium as Mg	mg/L	IS 3025: Part 46: 2023	44	30	100
10	Total Chloride as Cl	mg/L	IS 3025: Part 32: 1988	90	250	1000
<div><div>Reviewed by Water Analyst</div><div>Authorised Signatory Pavai Kumar-Executive Engineer</div></div>						
Note:						
1. The test results relate only to the items tested. & The result applied to the sample as received basis.						
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.						
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.						



CHENNAI METROPOLITAN WATER SUPPLY  
AND SEWERAGE BOARD  
WATER AND WASTE WATER TESTING LABORATORY  
QUALITY ASURANCE WING, No.1, NEW AVADI ROAD,  
KILPAUK, CHENNAI - 600010.



TC-14166

ULR No : TC141662590000358F		TEST REPORT - DRINKING WATER		Doc.No: CMWSSB/FRM/7.8/01	
Report No:	TR/2025/358-01	Report Issue Date:	26-03-2025	Page No	2 of 3
Challan No:	836	Challan Date:	24-03-2025	Amount (Rs)	2360/-

S. No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012	
					Acceptable Limit	Permissible Limit
11	Total alkalinity as CaCO <sub>3</sub>	mg/L	IS 3025: Part 23: 2023	268	200	600
12	Chlorine, Residual	mg/L	IS 3025: Part 26: 2021	<0.2	0.2	1.0
13	Ammonia as N	mg/L	IS 3025: Part 34: 1988	0.11	0.5	No Relaxation
14	Nitrite as NO <sub>2</sub>	mg/L	IS 3025: Part 34: 1988	0.05	-	-
15	Fluoride as F	mg/L	IS 3025: Part 60: 2008	<0.2	1.0	1.5
16	Sulphate as SO <sub>4</sub>	mg/L	IS 3025: Part 24: Sec 1: 2022	130	200	400
17	Iron as Fe	mg/L	IS 3025: Part 53: 2003	0.25	0.3	No Relaxation

*LUN*  
26/03/25  
Reviewed by  
Water Analyst

*P*  
26/03/2025  
Authorised Signatory  
Pavai Kumar-Executive Engineer

Note:

1. The test results relate only to the items tested. & The result applied to the sample as received basis.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.



CHENNAI METROPOLITAN WATER SUPPLY  
AND SEWERAGE BOARD  
WATER AND WASTE WATER TESTING LABORATORY  
QUALITY ASURANCE WING, No.1, NEW AVADI ROAD,  
KILPAUK, CHENNAI – 600010.

TEST REPORT - DRINKING WATER

Doc.No: CMWSSB/FRM/7.8/01

Report No:	TR/2025/358-02	Report Issue Date:	26-03-2025	Page No	3 of 3
Challan No:	836	Challan Date:	24-03-2025	Amount (Rs)	2360/-
Client Name & Address & Contact No / Email.ID	R.M.K. Senior Secondary School , R.S.M Nagar, Sundaracholapuram, Chennai 77.				
Sample Name	: Water	Sample Description	: Drinking water		
Sample Number	: 358	Sample Container	: Jerry Can		
Sample Submitted by	: Customer	Location & Date	: Bore Well Water, 24-03-2025		
Sample Quantity	: 2 Litres	Sample Condition	: Good		
Sample Received On	: 24-03-2025	Environmental Condition	: 23.0°C – 27.0°C		
Test Commenced on	: 24-03-2025	Test Completed on	: 25-03-2025		

S. No	Parameters	Unit	Result	Specification as per IS 10500:2012	
				Acceptable Limit	Permissible Limit
18	Albuminoid Nitrogen	mg/L	CMWSSB SOP/001 0.22	-	-
19	Oxygen Absorbed @ 4 Hrs	mg/L	IS 3025: Part 63: 2007 1.35	-	-
20	Phosphate as P	mg/L	IS 3025: Part 31: Sec 1: 2022 0.01	-	-

Remarks:

The tested sample is conformed to IS: 10500:2012 (RA: 2019) Drinking water specification with respect to above tested parameters.

-----End of Test Report-----

*L.M.W.*  
26/03/25  
Reviewed by  
Water Analyst

*P.K.*  
26/03/2025  
Authorised Signatory  
Pavai Kumar-Executive Engineer

Note:

1. The test results relate only to the items tested. & The result applied to the sample as received basis.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.